



## SECTION 10 21 13.19 - PLASTIC TOILET COMPARTMENTS

### **PART 1 GENERAL**

#### 1.1 SECTION INCLUDES

- A. Solid HDPE polymer partitions; Floor Anchored/Overhead Braced.
- B. Urinal Screens

#### 1.2 RELATED SECTIONS

- A. Section 05 50 00 - Metal Fabrications.
- B. Section 06 11 00 - Wood Framing: Concealed wood framing and blocking for compartment support.
- C. Section 10 28 00 - Toilet, Bath, and Laundry Accessories.

#### 1.3 REFERENCES

- A. ASTM International:
  - 1. ASTM E 84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
  - 2. ASTM D 1735 - Standard Practice for Testing Water Resistance of Coatings Using Water Fog Apparatus
  - 3. ASTM D 2247 - Standard Practice for Testing Water Resistance of Coatings in 100 percent Relative Humidity
- B. United States Green Building Council (USGBC): LEED Green Building Rating System.

#### 1.4 SUBMITTALS

- A. Submit under provisions of Section 01 30 00 - Administrative Requirements.
- B. Product Data: Provide manufacturer's data sheets on each product to be used, including:
  - 1. Literature indicating typical panel, pilaster, door, hardware and fastening.
  - 2. Preparation instructions and recommendations.
  - 3. Storage and handling requirements and recommendations.
  - 4. Installation methods.
- C. Shop Drawings:
  - 1. Dimensioned plans indicating layout of toilet compartments.
  - 2. Dimensioned elevations indicating heights of doors, pilasters, separation partitions, and other components; indicate locations and sizes of openings in compartment separation partitions for toilet and bath accessories to be installed in partitions; indicate floor and ceiling clearances.
  - 3. Details indicating anchoring components (bolt layouts) and methods for project conditions; indicate components required for installation, but not supplied by toilet compartment manufacturer.
- D. Selection Samples: For each finish product specified, one complete set of color selection guides representing manufacturer's full range of available colors, textures and patterns.
- E. Verification Samples: For each finish product specified, two samples representing actual product, color,

texture and pattern.

- F. LEED Green Building Rating System: Submit manufacturer's documentation of recycled content, in accordance with LEED credit calculations.
- G. Manufacturer's Certificates: Certify products meet or exceed specified requirements.

#### 1.5 DELIVERY, STORAGE, AND HANDLING

- A. Deliver, store and handle materials and products in strict compliance with manufacturer's instructions and recommendations and industry standards.
- B. Store products indoors in manufacturer's or fabricator's original containers and packaging, with labels clearly identifying product name and manufacturer. Protect from damage.
- C. Lay cartons flat, with adequate support to ensure flatness and to prevent damage to pre- finished surfaces.
- D. Do not store where ambient temperature exceeds 120 degrees F.

#### 1.6 PROJECT CONDITIONS

- A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.
- B. Do not deliver materials or begin installation until building is enclosed, with complete protection from outside weather, and building temperature maintained at a minimum of 60 degrees F.

#### 1.7 WARRANTY

- A. Manufacturers Standard Warranty: Provide warranty for Solid polymer HDPE Material: Against breakage, corrosion, and delamination for 25 years.

#### 1.8 COORDINATION

- A. Coordinate Work with placement of support framing and anchors in walls and ceilings.

### **PART 2 PRODUCTS**

#### 2.1 MANUFACTURERS

- A. Acceptable Manufacturers:
  - 1. ASI Accurate Partitions
  - 2. ASI Global Partitions
  - 3. Similar systems by other manufacturers are acceptable. subject to compliance with requirements herein and approval by the Architect.
- B. Requests for substitutions will be considered in accordance with provisions of Section 01 60 00.

#### 2.2 COMPARTMENTS AND SCREENS

- A. Toilet Compartments: Floor anchored/overhead braced solid polymer. NFPA 286 compliant.
  - 1. Compartment Depth and Width: As scheduled and indicated on Drawings.
  - 2. Door Width: 24 inches minimum; at ADA accessible compartments 36 inches minimum.
  - 3. Height Above Floor: As indicated on the drawings.
  - 4. Door/Panel Height: 55 inches.
  - 5. Pilaster Height: 82 inches.
- B. Privacy and Urinal Screens: Wall hung.
  - 1. Screen Panel Size: 24 inches wide by 48 inches high.

## 2.3 SOLID POLYMER TOILET COMPARTMENTS

- A. Doors, Panels, Screens, and Pilasters: Single sheet solid, homogeneous HDPE plastic material formed from waterproof, non-absorbent, high-density polyethylene resins; mark-resistant self-lubricating surface; edges finished smooth.
  - 1. Material: Solid, homogeneous HDPE; 1 inch thick.
  - 2. Material to be tested in accordance with, and pass the acceptance criteria of NFPA 286.
  - 3. Material shall be compliant with IBC 2012 or later and must be solid HDPE; foamed material not allowed.
  - 4. Edges: 1/4 inch radius machined edges.
  - 5. Heat Sink: Aluminum heat sink, to dissipate heat from incendiary devices used by vandals, attached to bottom of doors and panels.
- B. Finish: Pebble-textured homogeneous color throughout material. Color as selected from manufacturer's standard colors.
- C. Door Hardware: 8 inch aluminum wrap-around hinge.
  - 1. Hinges: Hinges shall be 8 inches and fabricated from heavy-duty extruded aluminum (6463-T5 alloy) with a brushed anodized finish with wrap-around flanges, surface mounted and through bolted to doors and pilasters. Hinges operate and are field set with adjustable nylon cams. Cams can be set in 30 degree increments.
  - 2. Latch: Anodized extruded aluminum, with housing, slide bolt and button.
  - 3. Strike and Keeper: Permitting emergency access by lifting the door until latch is clear of keeper; satin chrome-plated finish.
  - 4. Coat Hook and Bumper: Non-ferrous, chrome-plated, with black rubber tip for doorstop.
  - 5. Fastening Hardware: Manufacturer's standard, Type 304 stainless steel, No. 4 satin finish, theft-resistant barrel nuts and machine screws.
  - 6. Door Pulls: Non-ferrous, chrome-plated. Standard on ADA compartments. Two per ADA door.
- D. Mounting Brackets: Provide optional aluminum continuous brackets with theft resistant barrel nuts and shoulder screws.
- E. Pilaster Shoes: Type 304 Stainless Steel No. 4 satin finish. Easy Stall shoe shall be of a one piece design and integral to the mounting system and formed from 304 stainless steel 3 inch (76 mm) high with a No. 4 satin finish. Pilaster shoes are anchored to the pilaster with No. 10 stainless steel, vandal-resistant screws.
- F. Headrail: Manufacture's standard anodized aluminum rail with anti-grip profile.
- G. Pilaster Anchors: Floor Anchored/Overhead Braced.
  - 1. Easy Stall shoe system. 1/4 by 2 inch steel screws attach Easy Stall shoe to floor.
  - 2. Pilaster to be inserted into shoe and secured after height adjusted. Leveling adjustment to be concealed by pilaster shoe.
  - 3. Height/leveling adjustment to be made via machine thread bolts inserted into factory installed threaded insert in bottom of pilaster.

## PART 3 EXECUTION

### 3.1 EXAMINATION AND PREPARATION

- A. Inspect and prepare substrates using the methods recommended by the manufacturer for achieving best result for the substrates under project conditions. Clean surfaces thoroughly prior to installation.
- B. Do not proceed with installation until substrates have been prepared using the methods recommended by the manufacturer and deviations from manufacturer's recommended tolerances are corrected. Commencement of installation constitutes acceptance of conditions.
- C. If preparation is the responsibility of another installer, notify Architect in writing of deviations from manufacturer's recommended installation tolerances and conditions.
  - 1. Verify dimensions of areas to receive compartments.
  - 2. Verify locations of built-in framing, anchorage, bracing, and plumbing fixtures.

### 3.2 INSTALLATION

- A. Install in accordance with approved shop drawings and manufacturer's instructions.
- B. Fasten components to adjacent materials and to other components using purpose-designed fastening devices.
- C. Adjust pilaster anchors for substrate variations; conceal anchors with pilaster shoes.
- D. Equip each compartment door with hinges and door latch.
- E. Install door strike keeper on pilasters in alignment with door latch.
- F. Equip each compartment door with one coat hook and bumper.
- G. Installation Tolerances:
  - 1. Maximum variations from plumb or level: 1/8 inch.
  - 2. Clearance between wall surface and panels or pilasters: 1-1/2 inch maximum.

### 3.3 ADJUSTING

- A. Adjust and align hardware to uniform clearance at vertical edge of doors.
- B. Adjust adjacent components for consistency of line or plane.

### 3.4 PROTECTION

- A. Protect installed products until completion of project.
- B. Touch-up, repair or replace damaged products before Substantial Completion.
- C. Remove factory protective coverings and clean finish surfaces in accordance with manufacturer's instructions before substantial completion.

END OF SECTION